



MB

 GOVERNMENT OF DUBAI	Organization Unit: General Projects Department الوحدة التنظيمية: إدارة المشاريع العامة		 DUBAI MUNICIPALITY	
	Form sheet title:	Material Approval Form (MAF)		اسم النموذج:
	Doc Ref.	DM_GPD_P3_F10		رقم النموذج:

Submittal No.	MEP/M/E/20	Rev.	1	Date	19/01/2016	<input type="checkbox"/> New Submittal.	<input checked="" type="checkbox"/> Re-submittal
---------------	------------	------	---	------	------------	---	--

Project No.	PJ-10063	Project Code		End User	DM
Project Title	AL Qouz Abattoir				
L.E.	Mr.Saleh ALJohary	L.A.		MEP Eng.	MHD. BARGHOTH
Consultant	ArchDome Consulting Engineers		Contractor	AL THURATH AL ASEEL CONTRACTING & ELECTRO-MECHANICAL	
Sub-contractor	AL THURATH AL ASEEL CONTRACTING & ELECTRO-MECHANICAL		Trade		

RECEIVED


19 JAN 2016

Description / Technical Letrate: CABLE MANAGEMENT SYSTEM					
Attachments	<input checked="" type="checkbox"/> Sample.	<input checked="" type="checkbox"/> Technical Data.	<input type="checkbox"/> QA/QC Reports.	<input type="checkbox"/> Method Statement.	<input type="checkbox"/> Others
Area of Application / Location		All Bilding			
Specs Ref.		Dwg. Ref.		BOQ ref.	
Origin	UAE	Manufacturer Name:	DELTA		
Local Agent	PowerMax Trading L.L.C		e-mail / Tel.	06-5340294	
Contractor's Attestation					
Material / Submittal Comply with Specifications			<input checked="" type="checkbox"/> Yes. <input type="checkbox"/> Alternative.		
Details if Alternative:					


التراخيص والاعتمادات
 للمقاولات والكهربيكات (ذ.م.م.)
 P.O. Box 48324 - Dubai
Al Thurath Al Aseel
 Contracting & Elec. Mech (L.L.C.)

Certified By	Ragavendhiran Balakrishnan	Signature / Date	19/01/2016
--------------	----------------------------	------------------	------------


For Consultant

<input type="checkbox"/> No Objection <input checked="" type="checkbox"/> No Objection with Comments <input type="checkbox"/> Rejected
Date forwarded to DM 24/1/16... Date Received from DM 25/1/16... * The Proposed brand final approval Subject to the client approval * All cable tray accessories shall be from same manufacturer only, hand made accessories are not accepted. * The Proposed cable tray brand should be under 5 years warranty. * All cable tray should be hot dip galvanized
Consultant Authorized: with minimum 45 mm Signature / Date: 

For Dubai Municipality (DM)

<input type="checkbox"/> 1. Work may proceed. <input checked="" type="checkbox"/> 2. work may proceed subject to incorporation of comments. <input type="checkbox"/> 3. Revise & re-submit, work may proceed subject to incorporation of comments. <input type="checkbox"/> 4. Revise & re-submit, work may not proceed. <input type="checkbox"/> 5. Rejected.
Comments: * No welding or cutting work allowed * Size of A.L.L cable Management system shall be as per cable engineering calculation
DM Authorized:  Signature / Date: 25/1/2016

Consultant Final Decision:

<input type="checkbox"/> No Objection <input checked="" type="checkbox"/> No Objection with Comments <input type="checkbox"/> Rejected
Date Forwarded to contractor 22/1/2016
Consultant Authorized: Signature/Date: 

Comments:

as per above

 28/1/2016

Note:

Dubai municipality permission to proceed does not constitute acceptance or approval of materials developed or selected and does not absolve engineer/contractor and their subcontractors and suppliers from full compliance with contractual obligations including the quality of final product.