







309000000941

PROJECT NUMBER: RFX-2131300069						
CONSTRUCTION OF SURGE PROTECTION DEVICES FOR THE TRANSMISSION PIPELINE NETWORK AND ASSOCIATED WORKS AT VARIOUS LOCATIONS IN THE EMIRATES OF DUBAI						
MATERIALS APPROVAL - SUBMISSION FORM						
TO:			FROM:			
M/s: DUBAI ELECTRICITY & WATER AUTHORITY			M/s: AL HIJAZ MECHANICAL EQUIPMENT CO LLC			
MATERIAL SUBMITTAL NO : ELEC-02		BOQ Ref.No : 00		DATE : 06/10/2014		
Schedule of Components No : 26		RIVISION NO : 01		Drawing Ref.No : 000/000		Specification Ref.3.3.15 &3.4.12
Material Description		:CABLE TRAYS & TRUNKING				
Size & Quantity		: As per approved shopdrawing				
Area of Application		: For Control cables				
Manufacture Name&Address		:TRANSDELTA INT'L INDUSTRIES				
Country of Origin		:UAE				
Supplier Name & Address		:POWERMAX TRADING LLC				
Contractor Signature & Seal						
ENCLOSURES:		CONSULTANT COMMENTS:				
<input checked="" type="checkbox"/> 1. HQP PAGES <input checked="" type="checkbox"/> 2. SPECIFICATION PAGES <input type="checkbox"/> 3. TENDER DRAWINGS <input checked="" type="checkbox"/> 4. COMPLIANCE STATEMENT <input type="checkbox"/> 5. TECHNICAL DATA SHEET <input type="checkbox"/> 6. SHOP DRAWING <input checked="" type="checkbox"/> 7. TEST REPORTS		<input checked="" type="checkbox"/> 8. ISO&OTHER CERTIFICATES <input checked="" type="checkbox"/> 9. WARRANTY CERTIFICATE <input checked="" type="checkbox"/> 10. COMPANY PROFILE <input checked="" type="checkbox"/> 11. ORIGINAL CATALOGUE <input checked="" type="checkbox"/> 12. PREVIOUS APPROVALS <input checked="" type="checkbox"/> 13. PAST SUPPLY RECORDS <input type="checkbox"/> 14. SAMPLES		REFER TO THE ATTACHED COMMENTS  <b>MWH</b> P.O. Box 3020 Dubai - UAE		
DEWA(WD) COMMENTS:		DEWA(WD) COMMENTS:				
<input type="checkbox"/> APPROVED <input checked="" type="checkbox"/> APPROVED WITH COMMENTS AS NOTED <input type="checkbox"/> REVISE & RESUBMIT <input type="checkbox"/> RETURNED FOR MODIFICATIONS <input type="checkbox"/> NOT APPROVED - REJECTED		① All cable trays and trunking shall be hot dipped galvanized, heavy duty type, and PVC coated. ② Shall conform with DEWA Electricity regulation upon installation. ③ Cable routing shall be as per DEWA CSD approval and as per site condition. ④ (R-Type) Heavy duty Cable Tray to be provided. ⑤ Earth continuity connectors to be provided. ⑥ As per the manufacturer's recommendation tray to be installed.				
NOTE:		1. DEWA (WD) approval does not relieve either the Consultant or Contractor of their responsibilities / obligations under the Consultancy , Agreement or Contract. 2. DEWA - WD approval is subject to compliance of specifications. 3. Test Certificates shall be submitted at the time of delivery.				
SIGNATURE		    				
DATE		21/10/2014 21/10/2014 02 Nov 2014 25/10/2014				
DESIGNATION		Project Engineer Manager/Engineer-SCADA & IC Manager/Engineer-Electrical & Mech Manager/Engineer-Materials Manager - Projects SM - P & E (M)				

Copy Circulation : DMS / Project File / Material File / Project Engineer / Consultant / Contractor



Comments on Cable Trays & Trunking

Ref:-Submittal No-02/Rev-1/Transdelta Intl industries/ 06.10.2014

1. Contractor to comply with DEWA Electricity regulations.
2. Bend, Tee, Riser, etc. shall be prefabricated and to be supplied by manufacturer.
3. Sample to be submitted for approval.
4. Support system shall be from same manufacturer.
5. Uniformity of coating thickness will be subject to random site testing.



Project:RFX2131300069

Construction

of Surge Protection Devices for the Transmission Pipeline Network and  
Associated Works at Various Locations in the Emirates of Dubai

Client: M/s.Dubai Electricity & Water Authority

Consultant: M/s.MWH UK Ltd.

Contractor: M/s.Al Hijaz Mechanical Equipment Co LLC

**COMMENTS COMPLIANCE STATEMENT**

Material: Cable Trays & Trunking (Ref#ELEC-02)

Sn	Comments	Our Reply	Remarks
1	All cable tray /trunking accessories shall be supplied by manufacturer.	Comply	Cable tray manufactured by Transdelta and the exclusive supplier will be M/s.Power Max Trading. Please refer to country of origin chapter 4(country of origin)
2	Cable tray /trunking system shall be of heavy duty	Comply	
3	Cable tray shall be PVC coated.	Noted	As per the manufacturer standard polyester coating system will be provided.

